

ERDC/CERL SR-01-1

Construction Engineering
Research Laboratory



**US Army Corps
of Engineers®**

Engineer Research and
Development Center

User Guide and Specifications for Baked Phenolic Coating Systems Applied to Domestic Hot Water Heat Exchangers

Vincent F. Hock

January 2001

20010227 100

**Construction Engineering
Research Laboratory**

ERDC/CERL SR-01-1



**US Army Corps
of Engineers®**

Engineer Research and
Development Center

User Guide and Specifications for Baked Phenolic Coating Systems Applied to Domestic Hot Water Heat Exchangers

Vincent F. Hock

January 2001

Foreword

This study was conducted for the Center for Public Works (USACPW), which has more recently been reorganized into the Directorate of Military Programs, Headquarters, U.S. Army Corps of Engineers (HQUSACE), under the Facilities Engineering Application Program (FEAP). The technical monitor was Malcolm McLeod, CEMP-RI.

The work was performed by the Materials and Structures Branch (CF-M) of the Facilities Division (CF), Construction Engineering Research Laboratory (CERL). The CERL principal investigator was Vincent F. Hock. Martin J. Savoie is Chief, CEERD-CF-M, and L. Michael Golish is Chief, CEERD-CF. The Acting Technical Director of the Facility Acquisition and Revitalization business area is Dr. Paul A. Howdyshell. The Acting Director of CERL is William D. Goran. The CERL technical editor was William J. Wolfe, Technical Resources.

CERL is an element of the U.S. Army Engineer Research and Development Center (ERDC), U.S. Army Corps of Engineers. The Director of ERDC is Dr. James R. Houston and the Commander is COL James S. Weller.

Contents

Foreword.....	2
1 Executive Summary.....	5
Points of Contact	5
Units of Weight and Measure	6
2 Pre-Acquisition.....	7
Description of the Technology	7
Life Cycle Cost Analysis	7
3 Acquisition/Procurement.....	9
Potential Funding Sources	9
Technology Components and Sources	9
Procurement Documents.....	9
Corps of Engineers Guide Specification Section 15400 Plumbing, General Purpose	10
Corps of Engineers Guide Specification Section 15405 Plumbing, Hospital	11
Procurement Scheduling	12
4 Post-Acquisition.....	13
Initial Implementation.....	13
Operation and Maintenance of Technology.....	13
Service/Support Requirements	13
Performance Monitoring	13
Appendix: FEAP Ad Flyer, "Anti-Scale/Corrosion Resistant Coating"	14
CERL Distribution	17
Report Documentation Page.....	18

1 Executive Summary

Most domestic water storage heaters used in the Army consist of a removable U-tube bundle installed in the lower half of a horizontal or vertical cylindrical boiler tank. The copper U-tube bundle used in cement-lined carbon steel tanks requires periodic removal (in locations with high scaling tendencies, as often as every 90 days) and acid cleaning to remove the excessive (0.011-in. thick) scale formation on the water-side surfaces of the tube bundle. Total softening of the water to remove scale is not feasible because it renders the water corrosive to the piping system. To ensure water potability and to protect human health, scale dispersants are prohibited in such systems. To protect the copper tubing in the heat exchanger, a phenolic coating (rated for dry heat temperatures up to 300 °F) has been adapted for use on tube bundles with a typical operating pressure of about 12-15 psi, exposed to corrosive and scale conducive environments.

Points of Contact

Mr. Vincent F. Hock
U.S. Army Construction Engineering Research
Laboratories (CERL)
ATTN: CECER-FM
PO Box 9005
Champaign, IL 61826-9005
tel.: 217/373-6753
FAX: 217/373-7222

Directorate of Engineering and Housing (DEH)
ATTN: AFZF-DE-MNT
Bldg. 4218
Fort Hood, TX 76544-5057
tel.: 817/287-4405
FAX: 817/287-8249

Wisconsin Protective Coating Corp.
PO Box 8147
Green Bay, WI 54308-8147
tel.: 414/437-6561
FAX: 414/437-8083

Heresite Protective Coatings
822 S. 14th Street
PO Box 250
Manitowoc, WI 54221-0250
tel.: 800/558/7747
FAX: 920/684-0110

Units of Weight and Measure

U.S. standard units of measure are used throughout this report. A table of conversion factors for Standard International (SI) units is provided below.

1 Btu	=	100,000 therm = 1055.56 Joule
1 Btu/(hr-sq ft.- °F)	=	5.67826 W/(sq meter- C)
1 Btu/(lb- °F)	=	4186.8 Joule/(Kg- C)
1 gal (U.S.)	=	3.787412 l
1 gal (U.S.)/min	=	0.0630902 l/sec
1 mil	=	0.0000245 m
1 in.	=	25.4 mm = 0.0254 m
1 lb	=	0.453592 kg
1 lb/in ² (psi)	=	6894.76 Pas
1 lb/gal (U.S.)	=	0.1198264 kg/l

2 Pre-Acquisition

Description of the Technology

The U.S. Army Construction Engineering Research Laboratories (CERL) has adapted a baked-on phenolic coating, known as P-403, for use on the water-side of copper U-tube bundles for mitigation of corrosion/scaling induced failures. When the coatings are applied to copper tube heat exchanger bundles, the maximum reduction in heat transfer efficiency is approximately 5 percent over the life of the coatings. This outweighs the 60 percent heat transfer reduction associated with a 0.008-in. thick scale deposit after 90 days of operation.

The phenolic coating is manufactured by Heresite-Saekaphen of Manitowoc, WI, and has been undergoing preliminary laboratory evaluation and field demonstration at several locations for the past 4 years. The coating is rated for dry heat temperatures up to 300 °F, and can be applied through either a spraying or immersion process. The coating is 60 percent solids by weight and 41 percent solids by volume. The heat exchanger coating consists of four coats of pigment, forming a 0.004- to 0.006-in. (dry film thickness) base coat. Two additional coats of an unpigmented, baked phenolic coating create a 0.002-in. (dry film thickness) top coat. The pigmented base layer of the baked phenolic coating system is currently being used without the unpigmented top coat in carbon steel steam condensate return lines. In addition, the coatings can be applied to both new and previously scaled/corroded tube bundles or pipes.

Life Cycle Cost Analysis

The coating greatly reduced maintenance and repair costs for installations with corrosion and/or scaling problems associated with heat exchangers. The cost of the coating, including removing and reinstalling the tube bundle (for one bundle) is about \$800, and the annual cost avoidance is \$5050 per exchanger under the severe scaling conditions at Fort Hood, TX. Table 1 shows the overall cost savings as projected at a severe scaling site (Fort Hood) and a severe corrosive/erosive site (Fort Lewis, WA). These results can be extended to other Army installations.

Table 1. Simple payback for coating heat exchangers at Fort Hood and Fort Lewis.

Site	No. of Exchangers	Annual Cost of Problem	Cost of Coating All Exchangers	Simple Payback
Fort Hood	115	\$56,923	\$92,000	1.6 years
Fort Lewis	97	\$60,624	\$77,600	1.3 years

3 Acquisition/Procurement

Potential Funding Sources

Army installations may use the Maintenance and Repair "K" account funds to procure baked phenolic coating of domestic hot water heat exchangers.

Technology Components and Sources

Two manufacturers of the phenolic resin coating are:

Heresite Protective Coatings
PO Box 250
Manitowoc, WI 54221-0250
tel.: 800/558/7747
FAX: 414/684-0110

Wisconsin Protective Coating Corp.
PO Box 8147
Green bay, WI 54308-8147
tel.: 414/437-6561
FAX: 414/437-8083

It is recommended that the coating be applied and cured by the manufacturer.

Procurement Documents

The Corps of Engineers Guide Specifications (CEGS) 15400 *Plumbing, General Purpose*, section 2.10.3 shall be cited for application of the phenolic resin coating system on either old or new domestic hot water heat exchangers. For hospital applications, CEGS 15405, *Plumbing, Hospital*, section 2.13.3 shall be cited. These specifications are presented below.

Corps of Engineers Guide Specification Section 15400 Plumbing, General Purpose

2.10.3 Phenolic Resin Coatings

The phenolic resin coil coating system shall be a product specifically intended for use on steel, copper, copper alloy, and stainless steel water heating coils. All coating components shall be capable of withstanding dry heat temperatures up to 300 degrees F. All coating material shall meet the requirements of CFR 21 Part 175. The coating system shall consist of the following three components:

2.10.3.1 Wash Primer

The wash primer shall be composed of a combination of polyvinyl butyral and a heat hardening phenolic resin. The weight per gallon shall be between 7.0 lbs/gallon minimum and 7.4 lbs/gallon maximum.

2.10.3.2 Pigmented Base Coat

The pigmented baking phenolic base coat shall consist of heat hardening phenolic resins, suitable pigments of the earth type, and softening agents. It shall not contain drying oils or cellulose material. The weight per gallon shall be between 10.3 lbs/gallon minimum and 10.7 lbs/gallon maximum. The non-volatile solids content shall be between 60 percent minimum and 64 percent maximum by weight.

2.10.3.3 Clear Top Coat

The clear non-pigmented baking phenolic top coat shall have a weight per gallon of between 8.65 lbs/gallon minimum and 8.95 lbs/gallon maximum. The non-volatile solids content shall be between 48 percent minimum and 52 percent maximum by weight.

Corps of Engineers Guide Specification Section 15405 Plumbing, Hospital

2.13.3 Phenolic Resin Coating

NOTE: If interior erosion of the tubes at or near the tube sheet is expected to be a severe problem, change the wording of this paragraph and its subparagraphs to require the coating to be applied to the first 5 to 8 inches inside the tubes by brushing.

The phenolic resin coating shall be applied at either the coil or coating manufacturer's factory. The coil shall be chemically cleaned to remove any scale if present and to etch the metal surface. The exposed exterior surface of the coil shall be abrasively cleaned to white metal blast in accordance with SSPC SP 5. The coating shall be a product specifically intended for use on the material the water heating coils are made of (i.e., steel, copper, copper alloy, or stainless steel). All coating components shall be capable of withstanding temperatures up to 300 degrees F dry bulb; and meet the requirements of CFR 21 Part 175. [The entire exterior surface] [and] [the first 5 to 8 inches inside the tubes] of each coil shall be coated with the three component phenolic resin coating system. The system shall consist of the following: the wash primer, the pigmented base coat, and the clear top coat. Immediate and final cure times and temperatures shall be as recommended by the coating manufacturer.

2.13.3.1 Coating Coil Interiors

One coat of the wash primer component shall be applied by brushing or flooding. Several coats of the pigmented base component shall be applied by brushing, immersion, or flooding. Several coats of the clear top (non-pigmented) component shall be applied by brushing, immersion, or flooding, with exception of the final coat which may be applied by spraying.

2.13.3.2 Coating Coil Exteriors

One coat of the wash primer component shall be applied by flooding. Several coats of the pigmented base component shall be applied by immersion or flooding. Several coats of the clear top (non-pigmented) component shall be applied by immersion or flooding, with exception of the final coat which may be applied by spraying.

2.13.3.3 Coating Components

- a. Wash Primer. The wash primer component shall be composed of a combination of a polyvinyl butyral and heat hardening phenolic resin. The weight per gallon shall be between 7.0 lbs/gallon minimum and 7.4 lbs/gallon maximum.
- b. Pigmented Base. The pigmented base component shall be applied to dry film thickness of 0.004 to 0.006 in. The pigmented base shall consist of heat-hardening phenolic resins, suitable pigments of the earth type, and softening agents. It shall not contain drying oils or cellulose material. The weight per gallon shall be between 10.3 lbs/gallon minimum and 10.7 lbs/gallon maximum. The non-volatile solids content shall be between 60 percent minimum and 64 percent maximum by weight.
- c. Clear Top. The clear top (non-pigmented) component shall be applied until the dry film thickness of the total coating system is between 0.005 and 0.007 inch. The clear non-pigmented top coat shall have a weight per gallon of between 8.65 lbs/gallon minimum and 8.95 lbs/gallon maximum. The non-volatile solids content shall be between 48 percent minimum and 52 percent maximum by weight.

For background information on the development of the baked phenolic coating, see CERL Technical Report (TR) M-91/05/ADA231716, *Development and Testing of an Anti-Scale/Corrosion Resistant Coating for Domestic Hot Water Heat Exchangers* (CERL December 1990).

Procurement Scheduling

The lead time for having a heat exchanger bundle factory coated and cured is approximately 3 to 4 weeks, exclusive of shipping time. Multiple tube bundles can be coated simultaneously.

4 Post-Acquisition

Initial Implementation

Installation of factory-coated heat exchangers requires no specialized labor; these systems can be installed easily by in-house labor. Care must be taken however to ensure personnel safety any time high temperature hot water or steam lines are the subject of invasive work (i.e., opened or disconnected).

Operation and Maintenance of Technology

The operation and maintenance of the factory-coated heat exchanger bundle does not differ from the uncoated tube bundle. The amount of time between periodic inspections for scale or corrosion can be extended to 6 months.


Service/Support Requirements

The manufacturer and applicator of the phenolic coating can assist with the requirements of coated heat exchanger technology.

Performance Monitoring


Removing and inspecting coated heat exchangers is no different from the case of uncoated heat exchangers. It is anticipated that recoating of these systems will be required every 5 years based on site-specific water chemistry, shell-and-tube geometry, and operating parameters.

**Appendix: FEAP Ad Flyer,
“Anti-Scale/Corrosion Resistant Coating”**



**Innovative
Ideas for the
Operation,
Maintenance,
& Repair of
Army Facilities**


Anti-Scale/Corrosion Resistant Coating



Top left: Schematic of boiler with heat exchanger tube bundle.

Bottom left: Scaled bundle being removed for cleaning at Fort Hood, TX.

Right: Uncoated vs. coated tube bundles in use at Fort Hood.



Quick Payback, Increased Efficiency

PROBLEM: Domestic hot water heat exchangers can have two problems:

- Scale build-up decreases the heat transfer efficiency.
- Corrosion causes the tube bundles to leak.

Both conditions result in high maintenance and repair costs and inconvenience for building occupants.

TECHNOLOGY: A baked-on phenolic coating system prevents scale deposits and resists corrosion.

DEMO SITES:

- Fort Hood, TX - FY86
- Fort Bragg, NC - FY88
- Fort Lewis, WA - FY88

BENEFITS:

- Payback at Fort Hood was 6 months for the two coated tube bundles.
- Eliminates system downtime, hazardous acid cleaning, and labor costs.

CT-3/Jan 93

Coating Reduces Maintenance Costs

Technology Prevents Corrosion and Scaling

Domestic water storage heaters supply potable hot water to large buildings throughout the Army. In areas with hard water, the tube bundles in these heaters lose their heat transfer efficiency due to scale buildup. In regions with corrosive water, the tube bundles corrode and develop leaks. The U.S. Army Construction Engineering Research Laboratory (CERL) adapted a baked-on phenolic coating system for use on the water side of copper U-tube bundles. This coating system stops both scaling and corrosion-induced failures in potable hot water heaters. The system consists of a base coat formed by four coats of pigment and a top coat composed of two coats of an unpigmented, baked phenolic coating.

Coatings Benefits Demonstrated

Two coated tube bundles were installed in 1986 and 1987 in dining facilities at Fort Hood, TX. Before the coating was applied, Fort Hood maintenance personnel had to acid clean these scaled bundles every 90 days. The two coated tube bundles at Fort Hood have not required acid cleaning since their installation. This has eliminated the need for site personnel to handle and dispose of the chemicals. Instead, the coated coils have simply needed a high-pressure water rinse about every 2 years. In addition, the coating is expected to only reduce heat transfer efficiency by about 10 percent over its service life. This compares to a 60 percent reduction in heat efficiency caused by scale deposit after only 90 days of operation.

During FY88, one coated bundle was installed at Fort Bragg, NC, to combat a scaling problem. Results have been favorable at this site as well. Also in FY88, coated bundles were installed in two barracks water heaters at Fort Lewis, WA, which has corrosive water. To date, the coating has prevented corrosion. Research from the field test indicates that the coating could double the life expectancy of tube bundles in severely corrosive environments similar to Fort Lewis.

Market Analyses Show Savings

Market analyses were conducted at Forts Hood and Lewis to determine the cost savings for both scaling and corrosion sites. Fort Hood used to annually spend \$10,129 to acid clean the two uncoated, scaled heat exchangers every 90 days. The cost of the coating (including removal and reinstallation by DEH maintenance personnel) was about \$800 per tube bundle. Since the dining hall water facilities are used heavily, the simple payback for the two coated heat exchangers is only about 6 months. If Fort Hood coated all 115 of its bundles, the projected payback would be about 18 months. Corroded tube bundles at Fort Lewis are replaced about every 5 years at a high capital cost of \$1542 per exchanger. The DEH replaces an average of eight heat exchangers each year, which costs about \$12,300 per year. The estimated payback for coating all 97 heat exchangers at Fort Lewis would be about 14 months.

Procurement Information

For information on the baked-on coating's applications, refer to CEGS 15400 (Plumbing, General) section 2.10.4 and CEGS 15405 (Plumbing, Hospital) section 2.13.3. A FEAP user guide also is available from CERL. The coatings can be obtained from several vendors.

Points of Contact

Vince Hock, COMM 217-373-6753, or toll-free 800-USA-CERL (outside Illinois), 800-252-7122 (within Illinois); or USA-CERL, P.O. Box 9005, Champaign, IL 61826-9005.

Joe McCarty, COMM 703-428-7266, Headquarters, U.S. Army Corps of Engineers (HQUSACE), ATTN: CECW-ET, 441 G St., NW., Washington, DC 20314-1000.

Issued by USAEHSC, Fort Belvoir, VA, IAW AR 25-30.

U.S. GOVERNMENT PRINTING OFFICE: 1993-747-096



CERL Distribution

HQUSACE

ATTN: CEMP-RI (2)

Chief of Engineers

ATTN: CEHEC-IM-LH (2)

ATTN: HECSA Mailroom (2)

ATTN: CECC-R

Engineer Research and Development Center (Libraries)

ATTN: ERDC, Vicksburg, MS

ATTN: Cold Regions Research, Hanover, NH

ATTN: Topographic Engineering Center, Alexandria, VA

Defense Tech Info Center 22304

ATTN: DTIC-O

11

1/01

REPORT DOCUMENTATION PAGE

Form Approved
OMB No. 0704-0188

Public reporting burden for this collection of information is estimated to average 1 hour per response, including the time for reviewing instructions, searching existing data sources, gathering and maintaining the data needed, and completing and reviewing this collection of information. Send comments regarding this burden estimate or any other aspect of this collection of information, including suggestions for reducing this burden to Department of Defense, Washington Headquarters Services, Directorate for Information Operations and Reports (0704-0188), 1215 Jefferson Davis Highway, Suite 1204, Arlington, VA 22202-4302. Respondents should be aware that notwithstanding any other provision of law, no person shall be subject to any penalty for failing to comply with a collection of information if it does not display a currently valid OMB control number. PLEASE DO NOT RETURN YOUR FORM TO THE ABOVE ADDRESS.

1. REPORT DATE (DD-MM-YYYY) 01-2001		2. REPORT TYPE Final		3. DATES COVERED (From - To)	
4. TITLE AND SUBTITLE User Guide and Specifications for Baked Phenolic Coating Systems Applied to Domestic Hot Water Heat Exchangers				5a. CONTRACT NUMBER	
				5b. GRANT NUMBER	
				5c. PROGRAM ELEMENT NUMBER	
6. AUTHOR(S) Vincent F. Hock				5d. PROJECT NUMBER FEAP	
				5e. TASK NUMBER M3	
				5f. WORK UNIT NUMBER K92	
7. PERFORMING ORGANIZATION NAME(S) AND ADDRESS(ES) U.S. Army Engineer Research and Development Center (ERDC) Construction Engineering Research Laboratory (CERL) P.O. Box 9005 Champaign, IL 61826-9005				8. PERFORMING ORGANIZATION REPORT NUMBER ERDC/CERL SR-01-1	
9. SPONSORING / MONITORING AGENCY NAME(S) AND ADDRESS(ES) Headquarters, U.S. Army Corps of Engineers (HQUSACE) 441 G Street, NW. Washington, DC 20314-1000				10. SPONSOR/MONITOR'S ACRONYM(S) CEMP-RI	
				11. SPONSOR/MONITOR'S REPORT NUMBER(S)	
12. DISTRIBUTION / AVAILABILITY STATEMENT Approved for public release; distribution is unlimited.					
13. SUPPLEMENTARY NOTES Copies are available from the National Technical Information Service, 5285 Port Royal Road, Springfield, VA 22161.					
14. ABSTRACT Most domestic water storage heaters used in the Army consist of a removable U-tube bundle installed in the lower half of a horizontal or vertical cylindrical boiler tank. The copper U-tube bundle used in cement-lined carbon steel tanks requires periodic removal and acid cleaning to remove the excessive scale formation on the water-side surfaces of the tube bundle. Total softening of the water to remove scale is not feasible because it renders the water corrosive to the piping system. To ensure water potability and to protect human health, scale dispersants are prohibited in such systems. This study adapted a phenolic coating for use on tube bundles exposed to corrosive and scale conducive environments to protect the copper tubing in the heat exchanger.					
15. SUBJECT TERMS coatings heat exchangers user manuals					
16. SECURITY CLASSIFICATION OF:			17. LIMITATION OF ABSTRACT SAR	18. NUMBER OF PAGES 20	19a. NAME OF RESPONSIBLE PERSON Vincent F. Hock
a. REPORT Unclassified	b. ABSTRACT Unclassified	c. THIS PAGE Unclassified			19b. TELEPHONE NUMBER (in- clude area code) (217) 373-6753